


1. SCOPE

This document defines the issued index for the controlled maintained documents within the Power Systems Distribution Low Voltage Earthing Manual.

2. ISSUE RECORD

DATE	ISSUE NO	AUTHOR	AMENDMENT DETAILS
March 2000	1	S. Peacock	Initial Issue: 2 Pages
Sept 2003	2	A Darling	Withdraw Section 1,3 &4 Insert EART-01-002 Issue 1
Oct 2003	3	A Darling	Insert EART-01-004 Issue 1

3. ISSUE AUTHORITY

Author	Owner	Issue Authority
A. Graham	A Graham	S Wood Network Strategy Manager 

4. DISTRIBUTION LOW VOLTAGE EARTHING MANUAL INDEX

Document Title	Existing Ref.	New Ref.	Issue	Date
Low Voltage Earthing Policy		EART – 01 - 002	1	March 2002
Local Authority Housing – Provision of Earth Terminals		EART – 01 - 004	1	Nov. 2003
Scope	1	EART - 10 - 001	1	Withdraw
Abbreviations	2	EART - 10 - 002	1	July 97
Technical Introduction	3	EART - 10 - 003	1	Withdraw
Policy	4	EART - 10 - 004	1	Withdraw
Supply Neutral Conductor	5	EART - 10 - 005	1	July 97
Earthing Requirements for PME Networks	6	EART - 10 - 006	1	July 97
Application of PME and the Integration of Networks	7	EART - 10 - 007	1	July 97
Customers' Installations	8	EART - 10 - 008	1	July 97
Earthing Arrangements at Ground Mounted S/S	M.E.1	EART - 10 - 009	1	July 97
Earthing Arrangements at Pole Transformer (LV O/H)	M.E.2	EART - 10 - 010	1	July 97
Earthing Arrangements at Pole Transformer (LV U/G)	M.E.3	EART - 10 - 011	1	July 97
Application of PME to New O/H or U/G Network	M.E.4	EART - 10 - 012	1	July 97
Additional and Extensions to Existing PME Networks	M.E.5	EART - 10 - 013	1	July 97
Additions and Extensions to Existing Underground NON – PME Networks	M.E.6	EART - 10 - 014	1	July 97
Additions and Extensions to Existing Overhead NON – PME Networks	M.E.7	EART - 10 - 015	1	July 97
Modification to Whole or Part of an U/G Network for PME	M.E.8	EART - 10 - 016	1	July 97
SNE Customers with Separate Neutral and Earth Return to Substation	M.E.9	EART - 10 - 017	1	July 97
SNE Customers Connected to 300 m or more of Electrically Continuous non-insulated metallic sheathed cable	M.E.10	EART - 10 - 018	1	July 97
SNE Customers Connected to 300m or more of Electrically Continuous non-insulated metallic sheathed cable with 4 core waveform "piece in"	M.E.11	EART - 10 - 019	1	July 97
New Multi-Occupied Building with CNE Rising Services : Meter Positions Adjacent to each flat	M.E.12	EART - 10 - 020	1	July 97
Lighting Authority SNE Distributor fed from PME Service	M.E.13	EART - 10 - 021	1	July 97
Recommended method of supplying a caravan site	M.E.14	EART - 10 - 022	1	July 97
Recommendations for Connections of 240 volts and 110 volts Internal Distribution when supply is PME	M.E.15	EART - 10 - 023	1	July 97
Method of Bonding Gas Service Pipes to customer's Earth Terminal	M.E.16	EART - 10 - 024	1	July 97
Electricity Supply Regulations: Street Lighting Exemptions	Appendix 1	EART - 10 - 025	1	Dec 96